


<b>Certificate Valid Until:</b>	05 July 2019
<b>Applicant:</b>	H. Maier GmbH Friedrich List Strasse, Gammertingen, Germany
<b>Manufacturer:</b>	H. Maier GmbH Friedrich List Strasse, Gammertingen, Germany
<b>Product:</b>	Fused plug, non-rewirable
<b>Brand</b>	 (H. Maier GmbH)
<b>Model / Type Ref:</b>	M69
<b>Technical Data / Rating:</b>	Max. 13A, 250V~ Details See Page 3
<b>This Product Complies with Standard(s):</b>	IEC 60884-2-1:2006 IEC 60884-1:2002+A1:2006+A2:2013 GSO IEC 60884-2-1:2009 GSO IEC 60884-1:2009
<b>National Deviations Checked:</b>	Kingdom of Saudi Arabia, Kingdom of Bahrain, State of Qatar, United Arab Emirates, Sultanate of Oman, State of Kuwait, Republic of Yemen Type and shape of the plug: G

**Conclusions**

The Notified Body certifies that this Electrical Equipment has been found to comply with the essential requirements of the safety objectives and the requirements of the electromagnetic compatibility of the **Gulf Technical Regulation on Low Voltage Electrical Equipment and Appliances BD-142004-01** list (2) subjected to the Conformity Assessment Procedure set out in Annex (4).

1. It applies only to the product(s) submitted and as detailed in the Technical Construction File (TCF).
2. It does not imply that the Notified Body has performed any surveillance or control of the manufacture(s).
3. The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.
4. The manufacturer shall inform the Notified Body of any modifications made to the examined product; this may lead to additional approval work resulting in cancellation, amendment and/or reissuance of this Gulf Type Examination Certificate.

Intertek Testing Services Ltd. Shanghai  
Room 1605, No. 201 Nanquan Road (North), Pudong New  
District, Shanghai, China



Certification Officer:

Gary Hu

Issue Date: 06 July 2016

Signature:

**List of the Gulf Type Examination technical documentation prepared by the manufacturer which is retained by the Notified Body in the TCF:**

- Trade mark, model or reference of the equipment
- General description and operation of the equipment
- Leaflet, use instructions, copy of warnings
- Detailed description with conceptual design and manufacturing drawings, including:
- List of components, materials, sub-assemblies and circuits
- Explanations necessary for the understanding of the above
- Address of place(s) of manufacturer & storage
- List of the Gulf standards, if any, applied in full or in part, and descriptions of the solutions adopted to meet the essential requirements of the regulation where the Gulf standards have not been fully applied (risk assessment, proposed solutions)
- Results of design calculations made, examinations carried out, etc.
- Test reports or test certificates from in-house laboratory belonging to the manufacturer, if any
- Documentation of the solutions adopted by the manufacturer to ensure conformity of the production with the product specified in this certificate
- Description of the conformity assessment procedure followed

**Additional Information:**

**Flexible cords:** (Only cord with cross area 1,5mm<sup>2</sup> can be used for Kingdom of Saudi Arabia)

Plug Rating (A)	Cross-section Area (mm <sup>2</sup> )	Type of cords	Cable Manufacturer	
6	2X0,75	H03VVH2-F	BRUNO BALDASSARI+F.LLI SPA	
6	2X0,75	H05VVH2-F		
6	2X0.75	H05V2V2-F		
10	2X1.0	H05V2V2-F		
6	3G0.75	H03VV-F		
6	2X0.75	H05VV-F		
10	2X1.0	H05VV-F		
13	2X1.5	H05VV-F		
6	3G0.75	H05VV-F		
10	3G1.0	H05VV-F		
13	3G1.5	H05VV-F		
6	2X0.75	H05BQ-F		Coroplast - Fritz Müller GmbH & Co. KG
10	2X1.0	H05BQ-F		
6	3G0.75	H05BQ-F		
10	3G1.0	H05BQ-F		
13	2x1.5	H07BQ-F		
13	3G1.5	H07BQ-F		
6	3G0.75	H05RR-F	ELETTROBRESZIA SPA	
10	3G1.0	H05RR-F		
13	3G1.5	H05RR-F		
6	2X0.75	H05RR-F		
10	2X1.0	H05RR-F		
13	2X1.5	H05RR-F		
6	3G0.75	H05RN-F		
10	3G1.0	H05RN-F		
6	2X0.75	H05RN-F		
10	2X1.0	H05RN-F		
10	3G1.0	H07RN-F		
13	3G1.5	H07RN-F		
10	2x1.0	H07RN-F		
13	2X1.5	H07RN-F		

